



Certificate of conformity of the factory  
production control No. 3592/2019

Inspecta Latvia has granted this certificate as proof that

**Precast concrete products:**

**Solid slabs, series „MP” and “SP”, according to Annex**

PRODUCED BY:

**SIA „DAUGAVPILS DZELZSBETONS”**

Rūpniecības iela 1A, Daugavpils, LV-5420; Reg. No. 41503019513

ADDRESS OF THE MANUFACTURING PLANT:

SIA „Daugavpils dzelzsbetons”, Rūpniecības iela 1A, Daugavpils, LV-5420

CERTIFIED ACCORDING:

Certification scheme, based on initial inspection of the manufacturing plant and of factory production control, continuing surveillance, assessment and evaluation of factory production control.

PRODUCT COMPLIES WITH THE REQUIREMENTS OF STANDARD:

**LVS EN 13369:2023**

„Common rules for precast concrete products” declared properties: concrete compressive strength, durability, reinforcing/prestressing steel, fire resistance and detailing of product.

This certificate was first issued on 4 February 2019 and will remain valid as long as neither the standard, the construction product, nor the manufacturing conditions in the plant are modified significantly.

7 February 2025

**Mārtiņš Maskavs**  
Certification Manager



Certificate issued on 1 (one) page with the Annex on 1 (one) page



EN ISO/IEC 17065  
S1-182

**AS Kiwa Latvia**  
Skanstes iela 54, Rīga  
LV-1013, Latvija

P. +371 67 607 900  
[latvia@kiwa.com](mailto:latvia@kiwa.com)

[www.kiwa.com/lv](http://www.kiwa.com/lv)

CERTIFICATE

**Product:** solid slabs, series „MP”.

Characteristics	Declared properties of product	
	min	max
<b>Type (code)</b>	series „MP”	
<b>Concrete</b> Compressive strength, N/mm <sup>2</sup>	C25/30	C50/60
<b>Reinforcing steel</b> Ultimate tensile strength, N/mm <sup>2</sup> Tensile yield strength, N/mm <sup>2</sup>	525 550	
<b>Durability of product</b> Freeze resistance (F), cycles Exposure class		300 FX3
<b>Fire resistance (R), min</b>	Tabulated data (EN 1992-1-2)	
<b>Detailing of product</b>	According to design specification	

**Product:** prestressed solid slabs, series „SM”.

Characteristics	Declared properties of product	
	min	max
<b>Type (code)</b>	series „SM”	
<b>Concrete</b> Compressive strength, N/mm <sup>2</sup>	C25/30	C50/60
<b>Prestressing reinforcement</b> Tensile strength ( $f_{pk}$ ), N/mm <sup>2</sup> Tensile yield strength ( $f_{p0.1k}$ ), N/mm <sup>2</sup>	1770 1500	
<b>Durability of product</b> Freeze resistance (F), cycles Exposure class		200 XC2+XF2
<b>Fire resistance (R), min</b>	Tabulated data (EN 1992-1-2)	
<b>Detailing of product</b>	According to design specification	

7 February 2025

Mārtiņš Maskavs  
Certification Manager



EN ISO/IEC 17065  
S1-182

**AS Kiwa Latvia**  
Skanstes iela 54, Rīga  
LV-1013, Latvija

P. +371 67 607 900  
[latvia@kiwa.com](mailto:latvia@kiwa.com)

[www.kiwa.com/lv](http://www.kiwa.com/lv)